

Qualification Certificate

Clean rooms RY 13 Čisté prostory RY 13 – 1. NP

No. : VÚO_16_ČP_01_OQ

User: Výzkumný ústav organických syntéz a.s., č.p. 296, Rybitví 533 54

Location: Building RY 13, 1. NP

Type of qualification: Revalidation in the range of operational qualification

Cleanliness class: D/K

HVAC system and parameters of clean rooms class „D“, especially level of airborne particulate cleanliness, **comply** with relevant legislation (VYR-36, ČSN EN ISO 14644) and prove correct functioning.

Validity of certificate **March 2017**.

Certificate issued and approved:

Date: 15.4.2016



Ing. Hana Šulcová
Quality Manager